


THIS DOCUMENT IS THE PROPERTY OF KOOLTRONIC, INC. AND CONTAINS PROPRIETARY AND CONFIDENTIAL INFORMATION WHICH MUST NOT BE DUPLICATED, USED OR DISCLOSED OTHER THAN AS EXPRESSLY AUTHORIZED BY KOOLTRONIC, INC.

EC 14/170
REMOVED SURGE SUPPRESSOR
7/10/14
W/

REV	DATE	APPROVED	DESCRIPTION
1	9/31/06	SSS/AS	NEW DRAWING RELEASE
2	7/29/06	ROM	ADDED TERMINATIONS TO 6" & 27" HEATER WIRES
3	2/14/07	SSS/	CHG BLK 8" WIRE TO -94/-219
4	3/23/07	SS/ROM	33" WHT -13/-94 WAS -94-94-28"
5	1/2/08	SS/ROM	33" BLU -13/-94 WAS -94/-94-28" CHANGED (1) FAN WIRE TO BLK CHANGED TERMINALS ON BOTH FAN WIRES TO -04



DIGITAL THERMOMETER 0750-110-01 (230V)
DIGITAL THERMOMETER 0750-109-01 (115V)

(11) Wires

ALL DIMENSIONS ARE IN INCHES. DIMENSIONS DESIGNATED MM ARE IN MILLIMETERS. UNLESS OTHERWISE SPECIFIED TOLERANCES NON-ACCUMULATIVE		DRAWN STEVE SCHMIERER 9/31/06
TOL. ON INCHES .XX ± .02 .XXX ± .010 ANGULAR ± 1/2°	CHECKED JERRY STEDNICK 9/16/06	DATE 9/31/06
MATERIAL UNIT K4AC2RP17RFHV-1	MFG. ENG.	TITLE KOOLTRONIC, INC. HOPWELL, NJ VERMONTA, CA USA WIRING DIAGRAM AIR CONDITIONER
APPROVED B KRELELY 9/21/06	CODE IDENT. NO. 06223 C SCALE NONE	DWG. NO. WD-1094 SHEET 1 OF 1